

**Declaration of Performance
DoP**

No. 008-CPR-2013

- | | |
|---|--|
| 1. Product identification code: | IVS-2 |
| 2. Type, batch or serial number: | Part number:
254615
254615.01
254616.01
254616.02
254616.03
254616.04
254650.6K
254650.12K
254650.18K
254650.24K
254650.30K
254650.36K |
| 3. Intended use: | Voice alarm system installed in buildings |
| 4. Name and contact address of the manufacturer: | Honeywell Life Safety AS
P.O. Box 3514
N-3007 Drammen
Norway
e-mail: fire.safety@honeywell.com |
| 5. Name and contact address of authorized representative: | Not applicable |
| 6. System or systems of assessment and verification of constancy of performance of the construction product: | System 1 |
| 7. In case of the declaration of performance concerning a construction product covered by a harmonized standard: | |
| Name and identification number of the notified body: | Nemko AS, no. 0470 |
| has performed type testing in accordance with system 1 and has issued following certificate of constancy of performance: | 0470-CPD-0029 |
| 8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued: | Not applicable |



by Honeywell

9. Declared performance:

Essential characteristics	Performance	Harmonized technical specification
Performance under fire condition	Passed	EN 54-16:2008 Art.: 4, 5, 7, 10, 12, 16.5, 16.6, 16.7
Response delay (response time to fire)	Passed	EN 54-16:2008 Art.: 7.1, 7.4, 7.8, 12
Operational reliability	Passed	EN 54-16:2008 Art.: 4, 5, 6, 7, 8, 9, 11, 12, 13, 14
Durability of operational reliability: Temperature resistance	Passed	EN 54-16:2008 Art.: 16.4, 16.8
Durability of operational reliability: Impact and vibration resistance	Passed	EN 54-16:2008 Art.: 16.11, 16.12, 16.13
Durability of operational reliability: Electrical stability	Passed	EN 54-16:2008 Art.: 16.14, 16.15
Durability of operational reliability: Humidity resistance	Passed	EN 54-16:2008 Art.: 16.9, 16.10

The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Sven-Ingve Rasmussen, R&D Manager

Name and position

Drammen, 24.06.2013

Place and date of issue

Signature

NORWAY / Honeywell Life Safety AS

Lierstranda Industriområde, P.O. Box 3514, 3007 Drammen, Norway

E-mail: fire.safety@honeywell.com

Phone: +47 32 24 48 00

Internet: www.eltek-fs.com